

Ave Maria Utility Company, LLLP (AMUC) is very pleased to provide you with this year's Annual Water Quality Report. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source is the Lower Tamiami aquifer. The water is treated by nanofiltration, then chlorinated for disinfection. If you have any questions about this report or concerning your water utility, please contact the AMUC staff at 239-348-0248. We encourage our valued customers to be informed about their water utility. AMUC routinely monitors for contaminants in your drinking water according to federal and state laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2009.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

 Ave Maria
Utility Company
5076 Annunciation Circle, Suite 102
Ave Maria Florida 34142

 Ave Maria
Utility Company

2009 ANNUAL WATER QUALITY REPORT

 2010
Best Tasting
Drinking Water
- Florida AWWA -



PWS ID Number: 5114154

Ave Maria Utility Company, LLLP 2009 Monitoring Results for Contaminants in Drinking Water

Radiological Contaminants							
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Radium 226 or combined radium (pCi/l)	Quarterly 2007	No	0.25	0 - 1.0	0	5	Erosion of natural deposits
Inorganic Contaminants							
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	MCLG	MCL	Likely Source of Contamination	
Barium (ppm)	12/09	No	0.0056	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
Nitrate (as Nitrogen) (ppm)	12/09	No	0.04	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	
Sodium (ppm)	12/09	No	19	NA	160	Salt water intrusion; leaching from soil	
Chromium (ppb)	12/09	No	0.6	100	100	Discharge from steel and pulp mills; erosion of natural deposits	
Nickel (ppb)	12/09	No	1.1	NA	100	Pollution from mining and refining operations; natural occurrence in soils	
Stage 1 Disinfectant/Disinfection By-Product (D/DBP) Contaminants							
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected ¹	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine (ppm)	Monthly	No	2.25	1.14 - 3.1	MRDLG = 4	MRDL = 4	Water additive used to control microbes
Haloacetic Acids (five) (HAA5) (ppb)	Quarterly	No	14.54	9.7 - 13.37	NA	MCL = 60	By-product of drinking water disinfection
TTHM (ppb) [Total Trihalomethanes]	Quarterly	No	51.95	21.4 - 26.3	NA	MCL = 80/100	By-product of drinking water disinfection
Lead and Copper (Tap Water)							
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	AL Violation Y/N	90th Percentile Result	No. of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
Copper (tap water) (ppm)	09/09	No	0.351	1	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppm)	09/09	No	1	0	0	15	Corrosion of household plumbing systems; erosion of natural deposits

Notes:

¹ The result in the level detected column for TTHMs is the highest of the four quarterly running annual averages of results from all sampling sites.

Definitions:

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

ND: means not detected and indicates that the substance was not found by laboratory analysis.

Parts per million (ppm) or Milligrams per liter (mg/l): one part by weight of analyte to 1 million parts by weight of the water sample.

Parts per billion (ppb) or Micrograms per liter (µg/l): one part by weight of analyte to 1 billion parts by weight of the water sample.

Picocurie per liter (pCi/L): measure of the radioactivity in water.

Source Water Assessment:

In 2009, a source water assessment was conducted for our water system. The assessment found one potential source of contamination near the wells; a petroleum storage tank. The hazard level is considered to be moderate. Source water assessments are posted at <http://www.dep.state.fl.us/swapp/>.

Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Ave Maria Utility Company, LLLP is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.